

Data	Locul de prelevare	PARAMETRII FIZICO-CHIMICI															PARAMETRII BACTERIOLOGICI							
		Amoniu	Nitriti	Oxidab	pH	Fier	Alum	Turbid	Cl2lib	Cl2lrg	Durit	Cloruri	Conduc la 25°	Azotati	Sulfati	Activ alfa globala	Activ beta globala	Cul/ gust/ Miros	Clostrid. perfring	Entero	Ecoli	Bact. coli	Nr.col 22°C	Nr.col 37°C
		mg/l	mg/l	mgO ₂ /l	unit pH	mg/l	μg/l	NTU	mg/l	mg/l	°germ	mg/l	μS/cm	mg/l	mg/l	Bq/l	Bq/l		UFC /100ml	UFC /100ml	UFC /100ml	UFC /100ml	UFC/ ml	UFC/ml
C.M.A cf Ordonanta nr.7/2023		0.5	0.5	5	6,5/9,5	0.2	200	5	0,1/0,5	>5	250	2500	50	250	0.1	1	n.m.a		0	0	0	0	0	0
CONSUMATORI SFANTU GHEORGHE																								
07.02.	Scoala Gim.Varadi Jozsef, str.Benedek Elek nr.20	<0.020	<0.020	<0.50	7.61	<0.020		0.56	0.22	0	18.8	19.9	675	14.29	56.87			n.m.a		0	0	0	<1	<1
21.02.	Casa de cultura Konya Adam, str.Kossuth Lajos	<0.020	<0.020	<0.50	7.54	0.045		0.76	0.1	0	18.6	19.9	583	12.416	38,236			n.m.a		0	0	0	<1	<1
28.02.	Ozun, Magazin Bricomag., str.Gabor A.	<0.020	<0.020	<0.50	7.43	0.107		0.67	0.12	0	18.5	19.6	662	9.425				n.m.a		0	0	0	<1	<1
CONSUMATORI INTORSURA BUZAUZULUI																								
28.02.	Scoala Gim. M. Sadoveanu, str. Mihai Viteazul	<0.020	<0.020	<0.50	7.47	<0.020		0.31	0.1	0	16.6	9.8	382					n.m.a				0	<1	<1
CONSUMATORI TARGU SECUIESC																								
12.02.	Euroconstruct SRL, str.Mai nr.3	<0.020	<0.020	<0.50	6.94	<0.020		0.42	0.04	0	18.6	17.7	798	<5.00				n.m.a		0	0	0	25	21
12.02.	BancaCoop.Eurocoop, str.Libertatii nr.11	<0.020	<0.020	<0.50	6.95	<0.020		0.46	0.14	0.03	16.13	17.7	667	<5.00				n.m.a		0	0	0	<1	<1
CONSUMATORI COVASNA																								
27.02.	Primaria BRATES	0.05	<0.020	1.09	6.85		180.6	1.81	0.12	0.04	2.11	6.76	87	<5.00	8.37			n.m.a	0	0	0	0	<1	<1
CONSUMATORI ZALAN																								
27.02.	Scoala Gim. David Jozsef	<0.020	<0.020	<0.50	7.52	<0.020		0.63	0.14	0			677	<5.00				n.m.a		0	0	0	<1	<1
CONSUMATORI BODOC																								
27.02.	Primaria Bodoc	<0.020	<0.020	0.58	7.5	0.073		1.64	0.18	0			760	<5.00				n.m.a		0	0	0	<1	<1

APROBAT
Şef Compartiment SMI
ing.Szántó Susana



ÎNTOCMIT
Şef Laborator Apa Potabila Sf.Gheorghe
ing.Ugron Noémi

