

Data	Locul de prelevare	PARAMETRII FIZICO-CHIMICI															PARAMETRII BACTERIOLOGICI									
		Amoniu	Nitriti	Oxidab	pH	Fier	Alum	Turbid	Cl2lib	Cl2lrg	Durit	Cloruri	Conduc la 25°	Azotati	Sulfati	Mangan	Activ alfa globala	Activ beta globala	Cul/ gust/ Miros	Clostrid. perfring	Enteroc	Ecoli	Bact. coli	Nr.col 22°C	Nr.col 37°C	
		mg/l	mg/l	mgO ₂ /l	unit pH	mg/l	μg/l	NTU	mg/l	mg/l	°germ	mg/l	μS/cm	mg/l	mg/l	mg/l	Bq/l	Bq/l		UFC /100ml	UFC /100ml	UFC /100ml	UFC /100ml	UFC/ ml	UFC/ml	
C.M.A cf Ordonanta nr.7/2023		0.5	0.5	5	6,5/9,5	0.2	200	5	0,1/0,5	>5	250	2500	50	250	0.05	0.1	1	n.m.a		0	0	0	0	0	0	
CONSUMATORI SFANTU GHEORGHE																										
04.03.	Primarie, Ilieni	<0.020	<0.020	<0.50	7.38	0.08	<15	0.67	0.1	0		666	15.254	34.58	<0.01			n.m.a		0	0	0	<1	<1		
11.03.	Primarie, Arcus, str.Gabor Aron nr.237	<0.020	<0.020	<0.50	7.38	<0.020		0.81	0.11	0		828	15.968					n.m.a		0	0	0	<1	<1		
18.03.	Brutaria Zoemia, Coseni	<0.020	<0.020	<0.50	7.55	0.128		3.41	0.17	0.05		713	11.379					n.m.a		0	0	0	<1	<1		
25.03.	Cofetaria M&M CUKI, Sf.Gheorghe, str.Ciucului nr.7	<0.020	<0.020	<0.50	7.66	<0.020		0.26	0.1	0		662	13.783					n.m.a		0	0	0	<1	<1		
CONSUMATORI INTORSURA BUZAULUI																										
25.03.	Lazarescu Gabriel, Intorsura Buzaului str.Mestesugarilor nr.14	<0.020	<0.020	<0.50	7.66							368						n.m.a		0	0	0	<1	<1		
CONSUMATORI TARGU SECUIESC																										
13.03.	Euroconstruct SRL, str.Mai nr.3																			0	0	0	<1	<1		
27.03.	Lunga nr.124	<0.020	<0.020	<0.50	7.15	<0.020	<15	0.38	0.1	0.03	17.02	647	<5.00	13.38	0.01			n.m.a		0	0	0	<1	<1		
CONSUMATORI COVASNA																										
12.03.	Spital Orasenesc, str.Gheorghe Doja nr.23	<0.020	<0.020	1.2	6.97		91.28	1.94	0.15	0.04		85	<5.00					n.m.a	0	0	0	0	20	38		
19.03.	SC.RESTAURANT BACOLUX SRL	0.026	<0.020	0.83	6.97		100.9	3.24	0.33	0.08		73	<5.00					n.m.a		0	0	0	<1	<1		
CONSUMATORI VALEA CRISULUI																										
20.03.	Primarie, Valea Crisului	<0.020	<0.020	<0.50	7.59	<0.020		0.31	0.09	0		641	10.211					n.m.a		0	0	0	<1	<1		

APROBAT
Sef Compartiment SMI
ing.Szántó Susana



ÎNTOCMIT
Şef Laborator Apa Potabila Sf.Gheorghe
ing.Ugron Nómi

