

Data	Locul de prelevare	PARAMETRII FIZICO-CHIMICI																	PARAMETRII BACTERIOLOGICI							
		Amoniu	Nitriti	Oxidab	pH	Fier	Alum	Turbid	Cl2lib	Cl2lrg	Durit	Cloruri	Conduc la 25°	Azotati	Sulfati	Mangan	Activ alfa globala	Activ beta globala	Cul/ gust/ Miros	Clostrid. perfring	Entero	Ecoli	Bact. coli	Nr.col 22°C	Nr.col 37°C	
		mg/l	mg/l	mgO ₂ /l	unit pH	mg/l	µg/l	NTU	mg/l	mg/l	°germ	mg/l	µS/cm	mg/l	mg/l	mg/l	Bq/l	Bq/l		UFC /100ml	UFC /100ml	UFC /100ml	UFC /100ml	UFC/ ml	UFC/ml	
C.M.A cf Ordonanta nr.7/2023		0.5	0.5	5	6,5/9,5	0.2	200	4	0,1/0,5		≥5	250	2500	50	250	0.05	0.1	1	n.m.a		0	0	0	0	0	
CONSUMATORI SFANTU GHEORGHE																										
11.03.	Primarie, Arcus, str.Gabor Aron nr.237																	0.006	0.027							
15.04.	Scoala Gim.Gabor Aron, Chichis	<0.020	<0.020	0.51	7.62	<0.020		0.56	0.08	0			745	14.12					n.m.a		0	0	0	<1	<1	
15.04.	Cimitirul comun, Sf.Gheorghe str.Cetatii	<0.020	<0.020	0.58	7.61	<0.020		0.26	0.07	0			750	14.52					n.m.a		0	0	0	<1	<1	
22.04.	Scoala Gim.Tatrangi Sandor,Ozun str, Gabor Aron	<0.020	<0.020	<0.50	7.48	<0.020		3.41	0.17	0.05			713	18.46					n.m.a		0	0	0	<1	<1	
24.04.	Brookhaven SRL, Sf.Gheorghe, str.Jokai Mor nr.2	<0.020	<0.020	<0.50	7.66	<0.020		0.26	0.1	0			662	23.78					n.m.a		0	0	0	<1	<1	
REZERVOARE INTORSURA BUZAULUI																										
17.04.	Rezervor nr.1							0.58	0.18	0									n.m.a		0	0	0	<1	<1	
17.04.	Rezervor nr.2							1.62	0.16	0									n.m.a		0	0	0	<1	<1	
17.04.	Rezervor Saramas							0.81	0.13	0									n.m.a		0	0	0	<1	<1	
CONSUMATORI TARGU SECUIESC																										
13.03.	Euroconstruct SRL, str.Mai nr.3																	0.0005	0.011							
23.04.	Liceul Bod Peter,str.Ady Endre nr.20	<0.020	<0.020	<0.50	7.08	<0.020	<15	0.21	0.08	0	17.91	18.3	690	16.21	17.52	<0.01			n.m.a		0	0	0	<1	<1	
CONSUMATORI COVASNA																										
08.04.	Spitalul Orasenesc, str.Gabor A. nr.14																				0	0	0	0	<1	<1
	Bazin Cerat							3.26	0.21	0.05											0	0	0	0	<1	<1
	Bazin Montana							2.59	0.2	0.05											0	0	0	0	<1	<1
	Bazin Telechia							1.6	0.28	0.06											0	0	0	0	<1	<1
	Bazin Pachia							1.57	0.15	0.02											0	0	0	0	<1	<1
08.04.	Bazin Brates							1.49	0.1	0											0	0	0	0	<1	<1
23.04.	Scoala Gim Avram Iancu ,str.M.Eminescu nr.15	0.03	<0.020	1.07	6.63	0.021	31.5	1.28	0.19	0.06	3.23	8.85	111	<5.00	14.36	0.01	0.06		n.m.a		0	0	0	0	<1	<1
CONSUMATORI ANGHELUS																										
16.04.	Scola.Gim. Forro Elek, Anghelus	<0.020	<0.020	0.54	7.59	0.096		0.93	0.09	0			790	<5.00					n.m.a		0	0	0	0	<1	<1
CONSUMATOR SI REZERVOR GHELINTA																										
23.04.	Rezervor 250 mc, Ghelinta							0.29	0.07	0											0	0	0	0	<1	<1
23.04.	Magazin alimentar PROFI, Ghelinta	0.02	<0.020	<0.50	6.87	0.06	<15	0.35	0.11	0	11.01	69.2	465	<5.00	10.73	<0.01			n.m.a		0	0	0	0	<1	<1

APROBAT
Sef Compartiment SMI
ing.Szántó Susana



ÎNTOCMIT
Şef Laborator Apa Potabila Sf.Gheorghe
ing.Ugron Noémi

