

Data	Locul de prelevare	PARAMETRII FIZICO-CHIMICI															PARAMETRII BACTERIOLOGICI					
		Amoniu	Nitriti	Oxidab	pH	Fier	Turbid	Cl2lib	Cl2lrg	Durit	Cloruri	Conduc la 25°	Azotati	Sulfati	Activ alfa globala	Activ beta globala	Cul/gust/Miros	Entero	Ecoli	Bact. coli	Nr.col 22°C	Nr.col 37°C
		mg/l	mg/l	mgO ₂ /l	unit pH	mg/l	NTU	mg/l	mg/l	°germ	mg/l	μS/cm	mg/l	mg/l	Bq/l	Bq/l		UFC /100ml	UFC /100ml	UFC /100ml	UFC/ ml	UFC/ml
C.M.A cf Ordonanta nr.7/2023		0.5	0.5	5	6,5/9,5	0.2	5	0,1/0,5		>5	250	2500	50	250	0.1	1	n.m.a	0	0	0	0	0
CONSUMATORI COVASNA																						
17.01.	Sc Auto Zaha Srl, str.Cuza Vodă nr.8	0.039	<0.020	1.16	7.44		2.82	0.3	0.07	3.33	7.81	73					n.m.a	0	0	0	<1	<1
23.01.	Primaria Covasna, str.Piliske nr	0.026	<0.020	1	7.24		2.19	0.16	0.05	2.83	7.18	104					n.m.a	0	0	0	<1	<1
CONSUMATORI GHELINȚA																						
30.01.	Magazin alimentar I.F.A, nr.1623	0.026	<0.020	1.16	6.91	<0.020	0.41	0.22	0	10.5	68.3	461					n.m.a	0	0	0	<1	<1

APROBAT
 Șef Compartiment SMI
 ing.Szántó Susana



ÎNTOCMIT
 Șef Laborator Apa Potabila Sf.Gheorghe
 ing.Ugron Noémi

