

Data	Locul de prelevare	PARAMETRII FIZICO-CHIMICI																	PARAMETRII BACTERIOLOGICI							
		Amoniu	Nitriti	Oxidab	pH	Fier	Alum	Turbid	Cl2lib	Cl2lrg	Durit	Cloruri	Conduc la 25°	Azotati	Sulfati	Mangan	Activ alfa globala	Activ beta globala	Cu/ gust/ Miros	Clostrid. perfring	Entero	Ecoli	Bact. coli	Nr.col 22°C	Nr.col 37°C	
		mg/l	mg/l	mgO ₂ /l	unit pH	mg/l	μg/l	NTU	mg/l	mg/l	°germ	mg/l	μS/cm	mg/l	mg/l	mg/l	Bq/l	Bq/l		UFC /100ml	UFC /100ml	UFC /100ml	UFC /100ml	UFC/ ml	UFC/ml	
C.M.A cf Ordonanta nr.7/2023		0.5	0.5	5	6,5/9,5	0.2	200	4	0,1/0,5		≥5	250	2500	50	250	0.05	0.1	1	n.m.a		0	0	0	0	0	
CONSUMATORI + REZERVOARE SFANTU GHEORGHE																										
	Gradinita Arvacska, str.Romulus Cioflec nr.14	<0.020	<0.020	<0.50	7.47	<0.020		0.55	0.08	0			750	13.573					n.m.a		0	0	0	<1	<1	
	Rezervor Paius							0.32	0.29	0			745						n.m.a		0	0	0	<1	<1	
	Rezervor Pace							1	0.22	0									n.m.a		0	0	0	<1	<1	
	Rezervor 64 mc							0.82	0.09	0									n.m.a		0	0	0	<1	<1	
	Rezervor Bicfalau							0.36	0.1	0									n.m.a		0	0	0	<1	<1	
13.05.	Rezervor Lisnau							0.59	0.1	0									n.m.a		0	0	0	60	70	
22.05.	Casa Lux Constructiilor, str.Varadi J,nr.14/3	<0.020	<0.020	<0.50	7.61	<0.020		0.69	0.14	0			651	9.368					n.m.a		0	0	0	<1	<1	
27.05.	Scoala Gim.Ady Endre, str.Armatei Romane nr.25	0.022	<0.020	0.53	7.49	<0.020		0.36	0.09	0			645	16.115					n.m.a		0	0	0	<1	<1	
CONSUMATORI INTORSURA BUZAULUI																										
21.05.	Judecatoria , Str.Hanului nr.2	<0.020	<0.020	<0.50	7.2	<0.020		0.81	0.13	0	18.74	20.6	438	<5.00					n.m.a							
CONSUMATORI TARGU SECUIESC																										
08.05.	SC.Compact SRL, Str.Orban Balazs nr.47	0.02	<0.020	<0.50	6.9	<0.020		0.54	0.16	0	11.7	11.1	703	<5.00					n.m.a		0	0	0	<1	<1	
CONSUMATORI COVASNA																										
28.05.	Liceul Korosi Cs.Sandor, str.Stefen cel Mare nr.40	<0.020	<0.020	1.27	7.21		54.3	1	0.15	0.05			117	<5.00					n.m.a	0	0	0	0	<1	<1	

APROBAT
Sef Compartiment SMI
ing.Szántó Susana



ÎNTOCMIT
Șef Laborator Apa Potabila Sf.Gheorghe
ing.Ugrom Noémi

