

Data	Locul de prelevare	PARAMETRII FIZICO-CHIMICI																	PARAMETRII BACTERIOLOGICI							
		Amoniu	Nitriti	Oxidab	pH	Fier	Alum	Turbid	Cl2lib	Cl2lrg	Durit	Cloruri	Conduc la 25°	Azotati	Sulfati	Mangan	Activ alfa globala	Activ beta globala	Cul/ gust/ Miros	Clostrid. perfring	Entero	Ecoli	Bact. coli	Nr.col 22°C	Nr.col 37°C	
		mg/l	mg/l	mgO ₂ /l	unit pH	mg/l	µg/l	NTU	mg/l	mg/l	°germ	mg/l	µS/cm	mg/l	mg/l	mg/l	Bq/l	Bq/l		UFC /100ml	UFC /100ml	UFC /100ml	UFC /100ml	UFC/ ml	UFC/ml	
C.M.A cf Ordonanta nr.7/2023		0.5	0.5	5	6,5/9,5	0.2	200	4	0,1/0,5		≥5	250	2500	50	250	0.05	0.1	1	n.m.a		0	0	0	0	0	
CONSUMATORI SFANTU GHEORGHE																										
10.06.	Apa Tratata , APM Sf.Gh.																0.0095	0.053								
01.07.	Prezsmar Balint,str.Voican nr.48	<0.020	<0.020	0.57	7.4	<0.020		0.45	0.11	0	18.8	22.2	687	13.399					n.m.a		0	0	0	<1	<1	
10.07.	Inspectoratul Scolar Judetean, str.Victor Babes	<0.020	<0.020	0.36	7.54	0.023		0.39	0.16	0.01	17.88		734	15.42					n.m.a		0	0	0	<1	<1	
17.07.	Hotel Castel, str.Izvorului nr.2	<0.020	<0.020	0.68	7.38	0.072		1.12	0.06	0			698	9.934					n.m.a		0	0	0	<1	<1	
24.07.	Cabinet Med.Fam, str.Oltului nr.12	<0.020	<0.020	0.54	7.49	<0.020		0.54	0.05	0			678	12.172					n.m.a		0	0	0	<1	<1	
CONSUMATORI INTORSURA BUZAULUI																										
10.06.	Apa Tratata, Intorsura Buzaului																0.0055	0.11								
24.07.	Barcani,Primarie	<0.020	<0.020	0.51	7.36			0.48	0.3	0			420	5.655					n.m.a		0	0	0	<1	<1	
CONSUMATORI TARGU SECUIESC																										
10.07.	SC.BINASCO SRL, str.Gradinitei nr.3																				0	0	0	<1	<1	
31.07.	SC.WELAS SRL,str.Libertatii nr.21, bl.28	<0.020	<0.020	<0.50	6.81	<0.020		0.47	0.24	0.06			688	<5.00					n.m.a		0	0	0	<1	<1	
CONSUMATORI COVASNA																										
10.06.	Apa Tratata, Covasna																0.0099	0.021								
23.07.	Magazin Alimentar, Chiurus							76.9																		
29.07.	Liceul Korosi cs.Sandor, str.Stefan cel Mare nr.40	0.02	<0.020	1.82	6.97			129.9	2.36	0.08			172	<5.00					n.m.a		0	0	0			
CONSUMATOR BODOC																										
03.07.	Primaria Bodoc	<0.020	<0.020	0.59	7.12	0.047	58.4	0.68	0.05	0	15	24.6	824	12.24	25.73	<0.01			n.m.a		0	0	0	<1	<1	
CONSUMATOR GHIDFALAU																										
09.07.	Veres Marton, Ghidfalau nr.55B																				0	0	0	<1	<1	
CONSUMATOR VALEA CRISULUI																										
09.07.	Rezervor inmagazinare																				0	0	0	<1	<1	
16.07.	Primaria Valea Crisului	<0.020	<0.020	0.59	7.51	<0.020	86	0.38	0.18	0	16.4	24.6	648	5.297	28.62	0.02			n.m.a		0	0	0	<1	<1	
CONSUMATOR ZALAN																										
09.07.	Scoala Gim.David Jozsef, Zalan	<0.020	<0.020	<0.50	7.08	<0.020	63.1	0.35	0.07	0	14.3	15.6	993	11.77	52.91	0.03			n.m.a		0	0	0	<1	<1	
CONSUMATOR CATALINA																										
10.06.	Apa Tratata, Catalina																0.0028	0.15								
CONSUMATOR GHELINTA																										
10.06.	Apa Tratata, Ghelinta																0.006	0.05								

APROBAT
Sef Compartiment SMI
ing.Szántó Susana



ÎNTOCMIT
Şef Laborator Apa Potabila Sf.Gheorghe
ing.Ugron Noémi

