

Data	Locul de prelevare	PARAMETRII FIZICO-CHIMICI																	PARAMETRII BACTERIOLOGICI							
		Amoniu	Nitriti	Oxidab	pH	Fier	Alum	Turbid	Cl2lib	Cl2lrg	Durit	Cloruri	Conduc la 25°	Azotati	Sulfati	Mangan	Activ alfa globala	Activ beta globala	Cu/ gust/ Miros	Clostrid. perfring	Entero	Ecoli	Bact. coli	Nr.col 22°C	Nr.col 37°C	
		mg/l	mg/l	mgO ₂ /l	unit pH	mg/l	µg/l	NTU	mg/l	mg/l	°germ	mg/l	µS/cm	mg/l	mg/l	mg/l	Bq/l	Bq/l		UFC /100ml	UFC /100ml	UFC /100ml	UFC /100ml	UFC/ ml	UFC/ml	
C.M.A cf Ordonanta nr.7/2023		0.5	0.5	5	6,5/9,5	0.2	200	4	0,1/0,5		≥5	250	2500	50	250	0.05	0.1	1	n.m.a		0	0	0	0	0	
CONSUMATORI SFANTU GHEORGHE																										
05.08.	Cabinet Med.Gen, str.Erege	<0.020	<0.020	0.58	7.79	<0.020		0.36	0.13	0			654	16.2142					n.m.a		0	0	0	200	120	
19.08.	Cabinet Med.Gen, str.vasile Goldis	<0.020	<0.020	0.58	7.58	0.021		0.64	0.2	0.02			631	6.55					n.m.a		0	0	0	<1	<1	
27.08.	Primaria Arcus	<0.020	<0.020	0.59	7.52	<0.020		0.45	0.1	0			672	27.125					n.m.a		0	0	0	<1	<1	
CONSUMATOR+ REZERVOARE INTORSURA BUZAULUI																										
07.08.	Rezervor inmagazinare nr.1							0.58	0.15	0									n.m.a		0	0	0	<1	<1	
07.08.	Rezervor inmagazinare nr.2							0.62	0.12	0									n.m.a		0	0	0	<1	<1	
12.08.	Saramas-Hidrant str.Vacariei	<0.020	<0.020	<0.50	7.76	0		0.41	0.22	0.03	11.2	7	431	10.2187					n.m.a		0	0	0	<1	<1	
CONSUMATORI TARGU SECUIESC																										
28.08.	Benzinaria PETROM, str.Cernat nr.29	<0.020	<0.020	<0.50	6.81	<0.020		0.47	0.24	0.06			688	6.768					n.m.a		0	0	0	<1	<1	
CONSUMATORI +REZERVOARE COVASNA																										
07.08.	Liceul Korosi cs.Sandor, str.Stefan cel Mare nr.40																				0			<1	<1	
13.08.	Bazin Cerat							2.21	0.3	0.07											0	0	0	<1	<1	
13.08.	Bazin Montana							2.15	0.1	0											0					
13.08.	Bazin Pachia							1.55	0.1	0											0	0	0	<1	<1	
13.08.	Bazin Brates							1.31	0.1	0											0	0	0	<1	<1	
13.08.	Bazin Telechia							1.4	0.1	0											0	0	0	<1	<1	
29.07.	Liceul Korosi cs.Sandor, str.Stefan cel Mare nr.40	0.039	<0.020	1.04	7.46		112.37	2.33	0.1	0.03			189	11.482					n.m.a		0	0	0	0	<1	<1
CONSUMATOR GHIDFALAU																										
20.08.	Veres Marton, Ghidfalau nr.55B	<0.020	<0.020	0.61	7.71	<0.020	<15	0.28	0.1	0	17.1	23.6	742	8.211	23.39	0.03			n.m.a		0	0	0	<1	<1	
CONSUMATOR+REZERVOR GHELINTA																										
28.08.	Rezervor 250 mc							0.37	0.16	0.00									n.m.a		0	0	0	<1	<1	
28.08.	Primaria Ghelinta	<0.020	<0.020	<0.50	7.13	<0.020		0.39	0.12	0			431	35.079					n.m.a		0	0	0	<1	<1	

APROBAT
Sef Compartiment SMI
ing.Szántó Susana



ÎNTOCMIT
Şef Laborator Apa Potabila Sf.Gheorghe
ing.Ugron Noémi

